



**GREATER VISAKHAPATNAM MUNICIPAL CORPORATION  
FIRE PREVENTION WING**

From,  
The Commissioner,  
Greater Visakhapatnam  
Municipal Corporation  
Visakhapatnam.

To,  
The District Educational Officer,  
Visakhapatnam District,  
Visakhapatnam.

**Rc.No.035/RFO/FPW/GVMC/2022, Dt.04-02-2022**

**SUB:** Greater Visakhapatnam Municipal Corporation – Fire Prevention Wing - Existing Building of **M/s.Greendale School, D.No.1-1/5, Opp.YSR Stadium, Madhuwarawada, Visakhapatnam – Renewal of Fire No Objection Certificate Issued - Reg.**

- REF:**
1. Letter Rc.No: 5041/B2/97 of Director General, A.P Disaster Response & Fire Services Department, Dated: 12-03-2010.
  2. Delegation orders of the Commissioner, GVMC vide Rc.No.6721/2012/TP. Sec/G1 Dt: 13-09-2019.
  3. This office Fire No Objection Certificate for Occupancy issued vide FN28072000018, Dt.29-07-2020.
  4. Application Dt.21-01-2022 of M/s.Greendale School, D.No.1-1/5, Opp.YSR Stadium, Madhuwarawada, Visakhapatnam for Renewal of Fire No Objection Certificate.

\*\*\*

It is to inform that, vide reference 3<sup>rd</sup> cited, Fire No Objection Certificate for Occupancy was issued to M/s.Greendale School, D.No.1-1/5, Opp.YSR Stadium, Madhuwarawada, Visakhapatnam.

2) Further, vide reference 4<sup>th</sup> cited, an application is received by this office for issuance of Renewal of Fire No Objection Certificate to the same building.

3) Therefore, the Station Fire Officer, Fire Prevention wing, GVMC have inspected the premises of M/s.Greendale School, D.No.1-1/5, Opp.YSR Stadium, Madhuwarawada, Visakhapatnam on 02-02-2022 and submitted the following report.

4). Particulars of the building:

- (a) Address of the building : M/s.Greendale School, D.No.1-1/5, Opp.YSR Stadium, Madhuwarawada, Visakhapatnam
- (b) Total Plot Area : 61,281.00 Sq. Mtrs.
- (c) Height of the building : 10.00 Mtrs.
- (d) No. of floors : Ground + 02 upper floors
- (e) Type of occupancy : Educational (School)

5) The floor wise details

Sl. No.	Floor	Build up Area in Sq. Meters.	Occupancy Type
1.	Ground	856.00	Educational (School)
2.	First	856.00	Educational (School)
3.	Third	856.00	Educational (School)
	Total	<b>2568.00</b>	


6) The Builder has provided the following open spaces surrounding the building.

Direction	Open space Provided in Mtrs.
North (Front)	4.00
South	4.00
East	4.00
West	1.40

7) Means of Escape:

- The management provided One Internal Staircase with a width of 2.19 Mtrs. from ground floor to terrace.
- Note:- The management to provide additional staircase with a width of 1.50 Mtrs within 06 months from the date of issue of this NOC.

Contd.p.2



8) The Minimum Fire Safety Installations required & provided by the builder as per the Table-7 Part-IV of N.B.C of India 2016.

Sl. No.	Fire Safety Measures	Required	Provided	Deficit
1.	Fire Extinguishers as per IS:2190	27 Nos.	27 Nos.	Nil
2.	Hose Reels	03 Nos.	03 Nos.	Nil
3.	Manual Call Points	NR	03 Nos.	Nil
4.	Terrace Tank	10,000 Ltrs.	4,000 Ltrs.	6,000 Ltrs.
5.	Booster Pump	450 LPM	450 LPM	Nil

9) The management has remitted an amount of Rs.25,180/- vide challan No.2021-CH-15071, Dt.24-01-2022 at sowkaryam, GVMC, Visakhapatnam towards Fire precautionary fee and penal interest.

10) The Fire safety systems were tested by the Station Fire Officer, Fire Prevention Wing, GVMC during the inspection and performance found satisfactory and recommended for issuance of Renewal of Fire No Objection Certificate.


11) Therefore, **Renewal of Fire No Objection Certificate** is hereby issued to the Educational Building of M/s.Green Dale School, D.No.1-1/5, Opp.YSR Stadium, Madhuwarawada, Visakhapatnam subject to the following conditions:

i.	All the protection arrangements shall be maintained in good condition as seen during inspection
ii.	All the escape / exit routes shall not be kept locked / blocked or encroached
iii.	All the occupants must know the correct method of operation of the fire fighting system installed
iv.	Any loss of life or property due to non-functioning of fire safety measures and other installations shall be the responsibility of the management.
v.	All students / staff members of the institution shall be trained to operate the fire safety equipments during Emergency.
vi.	Addition / alteration, if any in the building may be obtained with prior permission from this department.
vii.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.

12) The management to provide additional staircase with width of 1.50 Mtrs. as per Clause 1.2 and 4.4.2.4.3 of Part-4, NBC 2016 and deficit of Water Tank within 06 months from the date of issue of this NOC.

13) The **Renewal of Fire No Objection Certificate** issued to M/s.Green Dale School, D.No.1-1/5, Opp.YSR Stadium, Madhuwarawada, Visakhapatnam **is valid from 29-07-2021 to 28-07-2024** and the Management shall submit the application for Renewal of Fire No Objection Certificate two (2) months before the date of expiry.

14) The issuing of Fire NOC will be without any Prejudice to take action against the unauthorized constructions if any made.

  
**(D.Niranjan Reddy)**  
**Regional Fire Officer**  
**Fire Prevention Wing,**  
**Greater Visakhapatnam Municipal Corporation,**  
**Visakhapatnam**

Copy to the Management, to M/s.Green Dale School, D.No.1-1/5, Opp.YSR Stadium, Madhuwarawada, Visakhapatnam.

Copy to the Chief City Planner, GVMC, Visakhapatnam.

