



GREATER VISAKHAPATNAM MUNICIPAL CORPORATION
FIRE PREVENTION WING

From:
The Commissioner,
Greater Visakhapatnam
Municipal Corporation,
Visakhapatnam.

To:
The District Educational Officer,
Visakhapatnam District,
Visakhapatnam.

Rc.No.239/RFO/FPW/GVMC/2024, Dt.20/06/2024

SUB: Greater Visakhapatnam Municipal Corporation – Fire Prevention Wing- Existing Building of M/s.Greendale School, Sy.No.1-1/5, Opp.YSR Cricket Stadium, Madhurawada, Visakhapatnam – **Renewal of Fire No Objection Certificate** – Issued - Regarding.

- REF:** 1. Letter Rc.No:5041/B2/97 of Director General, A.P.Disaster Response & Fire Services Department, Dated: 12-03-2010.
 2. Delegation orders of the Commissioner, GVMC vide Rc.No.6721/2012/TP. Sec/G1 Dt:13/09/2019.
 3. This office Fire No Objection Certificate for Occupancy issued vide FN28072000018, Dt.29-07-2020.
 4. This office Renewal of Fire No Objection Certificate for Occupancy issued vide Rc.No.035/RFOF/FPW/GVMC/2022, Dt.04-02-2022.
 5. Application Dated:04-02-2022 of M/s.Greendale School, Sy.No.1-1/5, Opp.YSR Cricket Stadium, Madhurawada, Visakhapatnam for Renewal of Fire NOC.

*** **

It is to inform that vide reference 3rd cited, Fire No Objection Certificate for Occupancy was issued to M/s.Greendale School, Sy.No.1-1/5, Opp.YSR Cricket Stadium, Madhurawada, Visakhapatnam and vide reference 4th cited, the management obtained Renewal of Fire No Objection Certificate.

2) Vide reference 5th cited, an application is received by this office for issuance of Renewal of Fire No Objection Certificate to the same building.

3) Therefore, the Inspection Committee of Fire Prevention Wing inspected the premises of M/s.Greendale School, Sy.No.1-1/5, Opp.YSR Cricket Stadium, Madhurawada, Visakhapatnam on 20-06-2024 and submitted the following report.

4) Particulars of The building:

a)	Address of the Premises	M/s.Greendale School, Sy.No.1-1/5, Opp.YSR Cricket Stadium, Madhurawada, Visakhapatnam
b)	Total Plot Area	61,281.07 Sq.Mtrs.
c)	Height of the Building	10.00 Mtrs.
d)	No of blocks/ floors	01 / Ground + 02 Upper Floors
e)	Type of occupancy	Educational (School)

5) The floor wise details.

Sl.	Floor	Area in Sq. Meters.	Type of Occupancy
-----	-------	---------------------	-------------------



No.			
1.	Ground	856.00	Educational (School)
2.	First	856.00	Educational (School)
3.	Second	856.00	Educational (School)
	Total	2568.00	

6) The Builder has provided the following open places all round building.

Direction	Open space provided (In Mtrs.)
North (Front)	04.00
South	04.00
East	04.00
West	01.40

7) Means Escape:

- The Management provided One Internal Staircase with width of 02.19 Mtrs. from Ground floor to Terrace which is sufficient for occupant load.

8) The Minimum Fire Safety Installations required & provided by the Builder as per Table-7, Part-IV of N.B.C. of India-2016:

Sl. No.	Fire Safety Measures	Required	Provided	Deficit
1.	Fire Extinguishers as per IS 2190	27 Nos.	27 Nos.	Nil
2.	Hose Reel	03 Nos.	03 Nos.	Nil
3.	Manual Call Points	NR	03 Nos.	Nil
4.	Terrace Tank	10,000 Ltrs.	04,000 Ltrs.	06,000 Ltrs.
5.	Booster Pump	450 LPM	450 LPM	Nil

9. The management has remitted an amount of Rs.38,520/- vide challan No.2024-CH-04782, Dt.19-06-2024 towards fire precautionary fees for 03 years renewal period.

10. The Fire safety systems were tested by the Inspection Committee, Fire Prevention Wing, GVMC during the inspection and performance found satisfactory and recommended for issuance of Renewal of Fire No Objection Certificate.

11. Therefore, **Renewal of Fire No Objection Certificate** is hereby issued to M/s.Greenale School, Sy.No.1-1/5, Opp.YSR Cricket Stadium, Madhurawada, Visakhapatnam subject to the following conditions:

i.	All the protection arrangements shall be maintained in good condition as seen during inspection
ii.	All the escape / exit routes shall not be kept locked / blocked or encroached
iii.	All the occupants must know the correct method of operation of the fire fighting system installed
iv.	Any loss of life or property due to non-functioning of fire safety measures and other installations shall be the responsibility of the management.
v.	All students / staff members of the institution shall be trained to operate the fire safety equipments during Emergency.
vi.	Addition / alteration, if any in the building may be obtained with prior permission from this department.
vii.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.

12. The management to provide One Additional Staircase with width of 01.50 Mtrs. as



per per NBC-2016, Part-IV, Table-3, 4 & 5 and Sec-1.2 & 4.4.2.4. within 06 months from the date of issue of this NOC.

13. The **Renewal of Fire No Objection Certificate** issued to M/s.Greendale School, Sy.No.1-1/5, Opp.YSR Cricket Stadium, Madhurawada, Visakhapatnam **is valid for three (03) years from 29-07-2024 to 28-07-2027** and the Management shall submit the application for Renewal of Fire No Objection Certificate two (2) months before the date of expiry.
14. The issuing of Fire NOC is without any prejudice to take action by GVMC against Unauthorized Construction, if any made.

Y HANUMANTHA RAO, RFO(YHR)-RFO(TP)-GVMC, O/o REGIONAL FIRE OFFICER-TOWN PLANNING-GVMC

Regional Fire Officer

Copy to the management, M/s. Greendale School, Sy.No.1-1/5, Opp.YSR Cricket Stadium, Madhurawada, Visakhapatnam.



Digitally Signed by Y
Hanumantha Rao
Date: 20-06-2024 16:24:00
Reason: Approved